

<b>TILE SLIP RATING REQUIREMENTS - TABLE 3B - SA HB 198:2014</b>		
<b>LOCATION</b>	<b>WET PENDULUM TEST</b>	<b>OIL-WET INCLINING PLATFORM TEST</b>
<b>STAIR TREADS, STAIRS &amp; LANDINGS - TABLE 3A - D.T.S. BCA APPLICATIONS</b>		
Stair treads and a stairway landing (nosings pendulum only) - DRY	P3	R10
Stair treads and a stairway landing (nosings pendulum only) - WET	P4	R11
<b>RAMP - TABLE 3A - TABLE 3A - D.T.S. BCA APPLICATIONS</b>		
Ramps not steeper than 1:14 gradient - DRY	P3	R11
Ramps not steeper than 1:14 gradient - WET	P4	R11
<b>HOTELS, OFFICES, PUBLIC BUILDINGS, SCHOOLS AND KINDERGARTENS</b>		
Entry foyers hotel, office, public buildings and internal lift lobbies - WET	P3	R10
Entry foyers hotel, office, public buildings and internal lift lobbies - TRANSITIONAL	P2	R9
Entry foyers hotel, office, public buildings and internal lift lobbies - DRY	P1	R9
Toilet facilities in offices, hotels, shopping centres	P3	R10
Hotel apartment bathrooms, en suites and toilets	P2	A
Hotel apartment kitchens and laundries	P2	R9
<b>SUPERMARKETS AND SHOPPING CENTRES</b>		
Fast food outlets, buffet food servery areas, food courts and fast food dining areas in shopping centres	P3	R10
Shop and supermarket fresh fruit and vegetable areas	P3	R10
Shop entry areas with external entrances	P3	R10
Supermarket aisles (except fresh food areas)	P1	R9
Other separate shops inside shopping centres- WET	P3	R10
Other separate shops inside shopping centres- DRY	P1	R9
<b>LOADING DOCKS, COMMERCIAL KITCHENS, COLD STORES, SERVING AREAS</b>		
Loading docks under cover and commercial kitchens	P5	R12
Serving areas behind bars in public hotels and clubs, cold stores & freezer	P4	R11
<b>SWIMMING POOLS AND SPORTING FACILITIES</b>		
Swimming pool ramps and stairs leading to water	P5	C
Swimming pool surrounds and communal shower rooms	P4	B
Communal changing rooms	P3	A
Undercover concourse areas of sports stadiums	P3	R10
<b>HOSPITALS &amp; AGED CARE FACILITIES</b>		
Bathrooms and en suites in hospitals and aged care facilities	P3	B
Wards and corridors in hospital and aged care facilities	P2	R9